

# Temora Sewage Treatment Plant

## EPA Licence Number 2523



Temora Shire Council  
 Temora Sewage Treatment Plant  
 Teal Street  
 TEMORA NSW 2666

**Location of Monitoring Point 5:** Sewage Treatment Pond 6 - discharge to utilisation area

**Monitoring Frequency required by licence:** monthly

**Date sample taken:** 16/05/2019  
**Date sample sent to laboratory:** 16/05/2019  
**Date data received from laboratory:** 3/05/2019  
**Date data published:** 16/05/2019  
**Date published within 14 days:** Yes

### Summary of Results for: April 2019

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	1	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	570	Yes
Oil & Grease	mg/L	20	1	No
pH	pH units	5.5 - 9.5	8.5	No
Total Suspended Solids	mg/L	40	21	No
Ammonia	mg/L	-	0.6	No
Conductivity	µS/cm	-	1030	No
Nitrate	mg/L	-	0.6	No
Total Nitrogen	mg/L	-	9	No
Total Phosphorous	mg/L	-	4.57	No