

Temora Sewage Treatment Plant

EPA Licence Number 2523



Temora Shire Council
 Temora Sewage Treatment Plant
 Teal Street
 TEMORA NSW 2666

Location of Monitoring Point 5: Sewage Treatment Pond 6 - discharge to utilisation area

Monitoring Frequency required by licence: monthly

Date sample taken: 23/07/2019
Date sample sent to laboratory: 23/07/2019
Date data received from laboratory: 9/07/2019
Date data published: 29/07/2019
Date published within 14 days: No

Summary of Results for: June 2019

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	2	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	30	Yes
Oil & Grease	mg/L	20	3	No
pH	pH units	5.5 - 9.5	8.3	No
Total Suspended Solids	mg/L	40	4	No
Ammonia	mg/L	-	2.2	No
Conductivity	µS/cm	-	934	No
Nitrate	mg/L	-	1.9	No
Total Nitrogen	mg/L	-	10	No
Total Phosphorous	mg/L	-	5.57	No