

# Temora Sewage Treatment Plant

## EPA Licence Number 2523



Temora Shire Council  
 Temora Sewage Treatment Plant  
 Teal Street  
 TEMORA NSW 2666

**Location of Monitoring Point 5:** Sewage Treatment Pond 6 - discharge to utilisation area

**Monitoring Frequency required by licence:** monthly

**Date sample taken:** 15/04/2019  
**Date sample sent to laboratory:** 15/04/2019  
**Date data received from laboratory:** 3/04/2019  
**Date data published:** 17/04/2019  
**Date published within 14 days:** Yes

### Summary of Results for: January 2019

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	4	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	130	Yes
Oil & Grease	mg/L	20	1	No
pH	pH units	5.5 - 9.5	8.5	No
Total Suspended Solids	mg/L	40	12	No
Ammonia	mg/L	-	1.2	No
Conductivity	µS/cm	-	976	No
Nitrate	mg/L	-	0.4	No
Total Nitrogen	mg/L	-	16	No
Total Phosphorous	mg/L	-	7.06	No

### Summary of Results for: February 2019

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	2	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	20	Yes
Oil & Grease	mg/L	20	4	No
pH	pH units	5.5 - 9.5	8.3	No

Total Suspended Solids	mg/L	40	3	No
Ammonia	mg/L	-	1.1	No
Conductivity	µS/cm	-	1030	No
Nitrate	mg/L	-	3.0	No
Total Nitrogen	mg/L	-	6	No
Total Phosphorous	mg/L	-	6.6	No

### Summary of Results for: March 2019

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	2	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	862	Yes
Oil & Grease	mg/L	20	1	No
pH	pH units	5.5 - 9.5	8.4	No
Total Suspended Solids	mg/L	40	6	No
Ammonia	mg/L	-	0.6	No
Conductivity	µS/cm	-	1060	No
Nitrate	mg/L	-	0.1	No
Total Nitrogen	mg/L	-	6	No
Total Phosphorous	mg/L	-	5.03	No