

Temora Sewage Treatment Plant

EPA Licence Number 2523



TEMORA
The Friendly Shire

Temora Shire Council
Temora Sewage Treatment Plant
Teal Street
TEMORA NSW 2666

Location of Monitoring Point 5: Sewage Treatment Pond 6 - discharge to utilisation area

Monitoring Frequency required by licence: monthly

Date sample taken: 11/02/2020
Date sample sent to laboratory: 11/02/2020
Date data received from laboratory: 25/02/2020
Date data published: 9/03/2020
Date published within 14 days: Yes

Summary of Results for: February 2020

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	4	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	1440	Yes
Oil & Grease	mg/L	20	6	No
pH	pH units	5.5 - 9.5	9.2	No
Total Suspended Solids	mg/L	40	6	No
Ammonia	mg/L	-	0.4	No
Conductivity	µS/cm	-	1110	No
Nitrate	mg/L	-	4.3	No
Total Nitrogen	mg/L	-	10	No
Total Phosphorous	mg/L	-	2.38	No