

Temora Sewage Treatment Plant

EPA Licence Number 2523



Temora Shire Council
 Temora Sewage Treatment Plant
 Teal Street
 TEMORA NSW 2666

Location of Monitoring Point 5: Sewage Treatment Pond 6 - discharge to utilisation area

Monitoring Frequency required by licence: monthly

Date sample taken: 2/03/2021
Date sample sent to laboratory: 2/03/2021
Date data received from laboratory: 31/03/2021
Date data published: 31/03/2021
Date published within 14 days: Yes

Summary of Results for: March 2021

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	26	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	9	No
Oil & Grease	mg/L	20	9	No
pH	pH units	5.5 - 9.5	9.8	Yes
Total Suspended Solids	mg/L	40	39	No
Ammonia	mg/L	-	0.1	No
Conductivity	µS/cm	-	711	No
Nitrate	mg/L	-	0.1	No
Total Nitrogen	mg/L	-	12	No
Total Phosphorous	mg/L	-	2.48	No