

# Temora Sewage Treatment Plant

## EPA Licence Number 2523



**TEMORA**  
*The Friendly Shire*

Temora Shire Council  
Temora Sewage Treatment Plant  
Teal Street  
TEMORA NSW 2666

**Location of Monitoring Point 5:** Sewage Treatment Pond 6 - discharge to utilisation area

**Monitoring Frequency required by licence:** monthly

**Date sample taken:** 8/04/2020  
**Date sample sent to laboratory:** 8/04/2020  
**Date data received from laboratory:** 4/05/2020  
**Date data published:** 6/05/2020  
**Date published within 14 days:** Yes

### Summary of Results for: April 2020

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	5	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	80	Yes
Oil & Grease	mg/L	20	3	No
pH	pH units	5.5 - 9.5	8.6	No
Total Suspended Solids	mg/L	40	32	No
Ammonia	mg/L	-	0.1	No
Conductivity	µS/cm	-	1020	No
Nitrate	mg/L	-	0.3	No
Total Nitrogen	mg/L	-	6	No
Total Phosphorous	mg/L	-	3.51	No