

Temora Sewage Treatment Plant

EPA Licence Number 2523



TEMORA
The Friendly Shire

Temora Shire Council
Temora Sewage Treatment Plant
Teal Street
TEMORA NSW 2666

Location of Monitoring Point 5: Sewage Treatment Pond 6 - discharge to utilisation area

Monitoring Frequency required by licence: monthly

Date sample taken: 4/08/2020
Date sample sent to laboratory: 4/08/2020
Date data received from laboratory: 18/08/2020
Date data published: 26/08/2020
Date published within 14 days: Yes

Summary of Results for: August 2020

| Pollutant | Unit of Measure | Limit | Test Result | Limit Exceeded |
|---------------------------|-----------------|----------------------|-------------|----------------|
| Biochemical Oxygen Demand | mg/L | 30 | 3 | No |
| Faecal Coliforms | per 100mL | 200 (80%) 600 (100%) | 40 | Yes |
| Oil & Grease | mg/L | 20 | 8 | No |
| pH | pH units | 5.5 - 9.5 | 7.7 | No |
| Total Suspended Solids | mg/L | 40 | 5 | No |
| Ammonia | mg/L | - | 5.6 | No |
| Conductivity | µS/cm | - | 808 | No |
| Nitrate | mg/L | - | 2.4 | No |
| Total Nitrogen | mg/L | - | 22 | No |
| Total Phosphorous | mg/L | - | 4.12 | No |