

# Temora Sewage Treatment Plant

## EPA Licence Number 2523



**TEMORA**  
*The Friendly Shire*

Temora Shire Council  
Temora Sewage Treatment Plant  
Teal Street  
TEMORA NSW 2666

**Location of Monitoring Point 5:** Sewage Treatment Pond 6 - discharge to utilisation area

**Monitoring Frequency required by licence:** monthly

**Date sample taken:** 1/07/2020  
**Date sample sent to laboratory:** 1/07/2020  
**Date data received from laboratory:** 27/08/2020  
**Date data published:** 31/08/2020  
**Date published within 14 days:** Yes

### Summary of Results for: July 2020

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	8	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	1	Yes
Oil & Grease	mg/L	20	6	No
pH	pH units	5.5 - 9.5	7.8	No
Total Suspended Solids	mg/L	40	16	No
Ammonia	mg/L	-	4.9	No
Conductivity	µS/cm	-	863	No
Nitrate	mg/L	-	1.7	No
Total Nitrogen	mg/L	-	20	No
Total Phosphorous	mg/L	-	4.11	No