

Temora Sewage Treatment Plant

EPA Licence Number 2523



Temora Shire Council
Temora Sewage Treatment Plant
Teal Street
TEMORA NSW 2666

Location of Monitoring Point 5: Sewage Treatment Pond 6 - discharge to utilisation area

Monitoring Frequency required by licence: monthly

Date sample taken: 23/03/2023
Date sample sent to laboratory: 23/03/2023
Date data received from laboratory: 20/04/2023
Date data published: 24/04/2023
Date published within 14 days: Yes

Summary of Results for: March 2023

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	4	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	38	No
Oil & Grease	mg/L	20	4	No
pH	pH units	5.5 - 9.5	9.1	No
Total Suspended Solids	mg/L	40	19	No
Ammonia as N	mg/L	-	0.1	No
Conductivity	µS/cm	-	974	No
Nitrate/Nitrite as N	mg/L	-	0.1	No
Nitrogen, total	mg/L	-	2	No
Total Kjeldahl Nitrogen	mg/L	-	2	No
Phosphorous, total	mg/L	-	2.64	No