

# Temora Sewage Treatment Plant

## EPA Licence Number 2523



Temora Shire Council  
Temora Sewage Treatment Plant  
Teal Street  
TEMORA NSW 2666

**Location of Monitoring Point 5:** Sewage Treatment Pond 6 - discharge to utilisation area

**Monitoring Frequency required by licence:** monthly

**Date sample taken:** 28/04/2023  
**Date sample sent to laboratory:** 28/04/2023  
**Date data received from laboratory:** 12/05/2023  
**Date data published:** 15/05/2023  
**Date published within 14 days:** Yes

### Summary of Results for: April 2023

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	4	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	4	No
Oil & Grease	mg/L	20	1	No
pH	pH units	5.5 - 9.5	9.1	No
Total Suspended Solids	mg/L	40	19	No
Ammonia as N	mg/L	-	0.1	No
Conductivity	µS/cm	-	900	No
Nitrate/Nitrite as N	mg/L	-	0.1	No
Nitrogen, total	mg/L	-	3	No
Total Kjeldahl Nitrogen	mg/L	-	3	No
Phosphorous, total	mg/L	-	3.72	No