

# Temora Sewage Treatment Plant

## EPA Licence Number 2523



Temora Shire Council  
Temora Sewage Treatment Plant  
Teal Street  
TEMORA NSW 2666

**Location of Monitoring Point 5:** Sewage Treatment Pond 6 - discharge to utilisation area

**Monitoring Frequency required by licence:** monthly

**Date sample taken:** 26/07/2023  
**Date sample sent to laboratory:** 26/07/2023  
**Date data received from laboratory:** 11/08/2023  
**Date data published:** 14/08/2023  
**Date published within 14 days:** Yes

### Summary of Results for: July 2023

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	7	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	120	No
Oil & Grease	mg/L	20	2	No
pH	pH units	5.5 - 9.5	7.5	No
Total Suspended Solids	mg/L	40	4	No
Ammonia as N	mg/L	-	8.7	No
Conductivity	µS/cm	-	863	No
Nitrate/Nitrate as N	mg/L	-	0.6	No
Nitrogen, total	mg/L	-	13	No
Total Kjeldahl Nitrogen	mg/L	-	12	No
Phosphorous, total	mg/L	-	3.89	No