

# Temora Sewage Treatment Plant

## EPA Licence Number 2523



Temora Shire Council  
Temora Sewage Treatment Plant  
Teal Street  
TEMORA NSW 2666

**Location of Monitoring Point 5:** Sewage Treatment Pond 6 - discharge to utilisation area

**Monitoring Frequency required by licence:** monthly

**Date sample taken:** 30/08/2023  
**Date sample sent to laboratory:** 30/08/2023  
**Date data received from laboratory:** 19/09/2023  
**Date data published:** 22/09/2023  
**Date published within 14 days:** Yes

### Summary of Results for: August 2023

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	2	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	78	No
Oil & Grease	mg/L	20	2	No
pH	pH units	5.5 - 9.5	8.0	No
Total Suspended Solids	mg/L	40	2	No
Ammonia as N	mg/L	-	12	No
Conductivity	µS/cm	-	903	No
Nitrate/Nitrate as N	mg/L	-	1.0	No
Nitrogen, total	mg/L	-	18	No
Total Kjeldahl Nitrogen	mg/L	-	17	No
Phosphorous, total	mg/L	-	1.48	No