

Temora Sewage Treatment Plant

EPA Licence Number 2523



Temora Shire Council
 Temora Sewage Treatment Plant
 Teal Street
 TEMORA NSW 2666

Location of Monitoring Point 5: Sewage Treatment Pond 6 - discharge to utilisation area

Monitoring Frequency required by licence: monthly

Date sample taken: 28.02.2024
Date sample sent to laboratory: 28.02.2024
Date data received from laboratory: 19.03.2024
Date data published: 22.03.2024
Date published within 14 days: Yes

Summary of Results for: December 2023

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	6	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	240	No
Oil & Grease	mg/L	20	<1	No
pH	pH units	5.5 - 9.5	8.2	No
Total Suspended Solids	mg/L	40	13	No
Ammonia as N	mg/L	-	0.5	No
Conductivity	µS/cm	-	878	No
Nitrate/Nitrite as N	mg/L	-	0.5	No
Nitrogen, total	mg/L	-	2	No
Total Kjeldahl Nitrogen	mg/L	-	2	No
Phosphorous, total	mg/L	-	4.48	No